

Stall Holder Name: \_\_\_\_\_

<b>LP GAS SAFETY</b> - Must be completed by all stallholders using LPG, including barbecues		<b>Y</b>	<b>N</b>	<b>ACTION IF NO</b>
<b>APPLIANCES</b>	Only certified appliances in use			
<b>Your stallholder site is an extension of your workplace. Stallholders must ensure:</b> <ul style="list-style-type: none"> <li>documented procedures for various tasks associated with the use of LP Gas are in place</li> <li>all personnel carrying out these tasks are adequately trained</li> <li>records are kept to demonstrate personnel have received instructions in the specific safe method</li> </ul>	Service history available			
	In good working condition			
	Safety devices not tampered with			
	Taps & knobs in good condition and marked			
	Not on a combustible surface			
	In a well vented location			
	Clearances from LPGas cylinder			
	External appliances not in an internal location			
	Appliance pressure does not exceed 3 kPa			
	<b>REGULATORS &amp; HOSES</b>	Hoses for appliance acceptable		
	Regulators in good condition			
	Regulator hose of approved material			
	Hoses in good condition			
	Protected from accidental damage			
	Hoses less than 3m in length			
<b>CYLINDERS</b>	Cylinder within 10-year test date			
	Cylinder in good condition			
	Cylinder connections checked for leaks			
	Located away from flammable materials and ignition source			
	Cylinder not blocking exit or path of travel			

Contact Details: Provide name and mobile number of representative on-site

Name: \_\_\_\_\_ Mobile: \_\_\_\_\_

This statement indicates that I/we, the stall-holder have implemented the following control measures for our site and activities during the (event name).....

Person responsible: \_\_\_\_\_ Signed: \_\_\_\_\_

Position: \_\_\_\_\_ Date: \_\_\_\_\_