

Bathurst Regional Council
 Water Filtration Plant
 EPA Licence Number 432



Date Sample Taken: 23/03/2022
 Date Sample Sent to Laboratory: 24/03/2022
 Date Data Obtained from Laboratory: 30/03/2022
 Date Data Published: 8/04/2022
 Data Published within 14 days: Yes

**Point 1 - Monthly Sample
 Discharge Quality Monitoring**

Date	BOD	Conductivity	pH	Total Suspended Solids
	mg/L	uS/cm	pH	mg/L
Limit	20	800	6.5 - 8.5	50
23/03/2022	2	346	7.3	5
Exceedance	No	No	No	No

Summary of Units of Measure

kL/d = kilolitres per day
 mg/L = milligrams per litre
 uS/cm = microsiemens per centimetre

Bathurst Regional Council
 Water Filtration Plant
 EPA Licence Number 432



Date Sample Taken: 27/04/2022
 Date Sample Sent to Laboratory: 28/04/2022
 Date Data Obtained from Laboratory: 4/05/2022
 Date Data Published: 6/05/2022
 Data Published within 14 days: Yes

**Point 1 - Monthly Sample
 Discharge Quality Monitoring**

Date	BOD	Conductivity	pH	Total Suspended Solids
	mg/L	uS/cm	pH	mg/L
Limit	20	800	6.5 - 8.5	50
27/04/2022	2	351	7.1	8
Exceedance	No	No	No	No

Summary of Units of Measure

kL/d = kilolitres per day
 mg/L = milligrams per litre
 uS/cm = microsiemens per centimetre