

**Bathurst Regional Council
Water Filtration Plant
EPA Licence Number 432**



Date Sample Taken: 16/03/2022
Date Sample Received at Laboratory: 17/03/2022
Date Data Obtained from Laboratory: 24/03/2022
Date Data Published: 4/04/2022
Data Published within 14 days: Yes

**Point 1 - Weekly Sample
Discharge Quality Monitoring**

Date	Aluminium
	mg/L
Limit	2
16/03/2022	0.24
Exceedance	No

Summary of Units of Measure

mg/L = milligrams per litre

**Bathurst Regional Council
Water Filtration Plant
EPA Licence Number 432**



Date Sample Taken: 23/03/2022
Date Sample Received at Laboratory: 24/03/2022
Date Data Obtained from Laboratory: 30/03/2022
Date Data Published: 4/04/2022
Data Published within 14 days: Yes

**Point 1 - Weekly Sample
Discharge Quality Monitoring**

Date	Aluminium
	mg/L
Limit	2
23/03/2022	0.18
Exceedance	No

Summary of Units of Measure

mg/L = milligrams per litre

Bathurst Regional Council
Water Filtration Plant
EPA Licence Number 432



Date Sample Taken: 30/03/2022
Date Sample Received at Laboratory: 31/03/2022
Date Data Obtained from Laboratory: 7/04/2022
Date Data Published: 8/04/2022
Data Published within 14 days: Yes

**Point 1 - Weekly Sample
Discharge Quality Monitoring**

Date	Aluminium
	mg/L
Limit	2
30/03/2022	0.24
Exceedance	No

Summary of Units of Measure

mg/L = milligrams per litre

**Bathurst Regional Council
Water Filtration Plant
EPA Licence Number 432**



Date Sample Taken: 27/04/2022
Date Sample Received at Laboratory: 28/04/2022
Date Data Obtained from Laboratory: 4/05/2022
Date Data Published: 6/05/2022
Data Published within 14 days: Yes

**Point 1 - Weekly Sample
Discharge Quality Monitoring**

Date	Aluminium
	mg/L
Limit	2
27/04/2022	1.31
Exceedance	No

Summary of Units of Measure

mg/L = milligrams per litre