

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**



Date Sample Taken: 6/01/2020
Date Sample Sent to Laboratory: 7/01/2020
Date Data Received from Laboratory: 13/01/2020
Date Data Published: 16/01/2020
Data Published within 14 days: Yes

**Point 1- Weekly Sample
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
6/01/2020	4	8	3.3	2	7.5	0.30	5
Exceedance	No	No	No	No	No	No	No

**Point 3 - Weekly Sample
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
6/01/2020	0	1900	0.0	0	0.0	0	0

**Point 4 - Weekly Sample
Environmental Monitoring 50m Upstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
6/01/2020	0	1300	0	0	0.0	0	0

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres