

**Bathurst Regional Council  
Waste Water Treatment Works  
EPA Licence Number 1647**

**Date Data Published:**

**31/01/2023**

**Data Published within 14 days:**

**Yes**

**Point 1 - Final Effluent**

Date	Volume Discharged
	kL/d
24/01/2023	10,305
25/01/2023	9,176
26/01/2023	8,807
27/01/2023	8,830
28/01/2023	8,733
29/01/2023	8,532
30/01/2023	8,482

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

**Summary of Units of Measure**

kL/d = kilolitres per day



**SUSTAINABLE BATHURST**  
A BETTER FUTURE  
AN INITIATIVE OF BATHURST REGIONAL COUNCIL