

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

10/02/2023

Data Published within 14 days:

Yes

Point 1 - Final Effluent

| Date | Volume Discharged |
|------------|-------------------|
| | kL/d |
| 31/01/2023 | 12,022 |
| 1/02/2023 | 9,603 |
| 2/02/2023 | 8,751 |
| 3/02/2023 | 10,153 |
| 4/02/2023 | 9,099 |
| 5/02/2023 | 9,449 |
| 6/02/2023 | 8,381 |

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL