

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Sample Taken: 15/03/2023
 Date Sample Received at Laboratory: 16/03/2023
 Date Data Received from Laboratory: 23/03/2023
 Date Data Published: 24/03/2023
 Data Published within 14 days: Yes

**Point 1- Weekly Sample
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
15/03/2023	2	9	8.9	2	7.42	0.75	5
Exceedance	No	No	No	No	No	No	No

**Point 3 - Weekly Sample
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
15/03/2023	NR	820	NR	NR	NR	NR	NR

**Point 4 - Weekly Sample
Environmental Monitoring Upstream of Wastewater Treatment Works**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
15/03/2023	NR	530	NR	NR	NR	NR	NR

Summary of Units of Measure

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres
 NR = Not required

