

**Bathurst Regional Council  
Waste Water Treatment Works  
EPA Licence Number 1647**

Date Sample Taken: 12/06/2024  
 Date Sample Received at Laboratory: 13/06/2024  
 Date Data Received from Laboratory: 13/06/2024  
 Date Data Published: 25/06/2024  
 Data Published within 14 days: Yes

**Point 1- Weekly Sample  
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
<b>Limit</b>	<b>30</b>	<b>600</b>	<b>20.0</b>	<b>10</b>	<b>6.5 - 8.5</b>	<b>2.00</b>	<b>30</b>
12/06/2024	2	110	8	2	7.1	0.30	5
Exceedance	No	No	No	No	No	No	No

**Point 3 - Weekly Sample  
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
12/06/2024	2	300	0.6	2	7.4	0.06	14

**Point 4 - Weekly Sample  
Environmental Monitoring Upstream of Wastewater Treatment Works**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
12/06/2024	2	180	0.7	2	7.4	0.09	17

**Summary of Units of Measure**

mg/L = milligrams per litre  
 CFU/100mL = colony forming units per 100 millilitres  
 NR = Not required

