

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

23/07/2024

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
9/07/2024	13,044
10/07/2024	11,840
11/07/2024	11,822
12/07/2024	11,937
13/07/2024	9,731
14/07/2024	9,362
15/07/2024	9,535

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day

