

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

15/08/2024

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
6/08/2024	9,472
7/08/2024	9,765
8/08/2024	9,196
9/08/2024	9,789
10/08/2024	9,580
11/08/2024	9,751
12/08/2024	9,367

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day

