

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Sample Taken: 2/10/2024
 Date Sample Received at Laboratory: 3/10/2024
 Date Data Received from Laboratory: 11/10/2024
 Date Data Published: 17/10/2024
 Data Published within 14 days: Yes

**Point 1- Weekly Sample
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
2/10/2024	2	34	6.7	2	7.2	0.56	8
Exceedance	No	No	No	No	No	No	No

**Point 3 - Weekly/Monthly Sample
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
2/10/2024	2	180	0.5	4	7.8	0.05	14

**Point 4 - Weekly/Monthly Sample
Environmental Monitoring Upstream of Wastewater Treatment Works**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
2/10/2024	2	94	0.5	4	7.9	0.05	14

Notes
 mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres
 Monitoring and Recording Conditions: Point 1 - All pollutants monitored weekly. Points 3 & 4 - Faecal Coliforms monitored weekly, all other pollutants monitored monthly.
 NR = Not required

