

Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647

Date Sample Taken: 23/10/2024
 Date Sample Received at Laboratory: 24/10/2024
 Date Data Received from Laboratory: 30/10/2024
 Date Data Published: 1/11/2024
 Data Published within 14 days: Yes

Point 1- Weekly Sample
Discharge to Macquarie River

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
23/10/2024	2	20	7.2	2	7.2	0.48	5
Exceedance	No	No	No	No	No	No	No

Point 3 - Weekly/Monthly Sample
Environmental Monitoring 50m Downstream of Point 1

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
23/10/2024	NR	290	NR	NR	NR	NR	NR

Point 4 - Weekly/Monthly Sample
Environmental Monitoring Upstream of Wastewater Treatment Works

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
23/10/2024	NR	200	NR	NR	NR	NR	NR

Notes

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres
 Monitoring and Recording Conditions: Point 1 - All pollutants monitored weekly. Points 3 & 4 - Faecal Coliforms monitored weekly, all other pollutants monitored monthly.
 NR = Not required



SUSTAINABLE BATHURST
 A BETTER FUTURE
 AN INITIATIVE OF BATHURST REGIONAL COUNCIL