

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Sample Taken:	30/10/2024
Date Sample Received at Laboratory:	31/10/2024
Date Data Received from Laboratory:	5/11/2024
Date Data Published:	11/11/2024
Data Published within 14 days:	Yes

**Point 1- Weekly Sample
Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
30/10/2024	2	110	7.5	2	7.3	0.40	6
Exceedance	No	No	No	No	No	No	No

**Point 3 - Weekly/Monthly Sample
Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
30/10/2024	2	170	0.4	2	7.8	0.05	8

**Point 4 - Weekly/Monthly Sample
Environmental Monitoring Upstream of Wastewater Treatment Works**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
30/10/2024	2	440	0.4	2	7.9	0.05	7

Notes

mg/L = milligrams per litre
 CFU/100mL = colony forming units per 100 millilitres
 Monitoring and Recording Conditions: Point 1 - All pollutants monitored weekly. Points 3 & 4 - Faecal Coliforms monitored weekly, all other pollutants monitored monthly.
 NR = Not required



SUSTAINABLE BATHURST
 A BETTER FUTURE
 AN INITIATIVE OF BATHURST REGIONAL COUNCIL