

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

28/11/2024

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
12/11/2024	9,169
13/11/2024	5,556
14/11/2024	14,002
15/11/2024	8,652
16/11/2024	7,952
17/11/2024	7,589
18/11/2024	9,947

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL