

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

28/11/2024

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
19/11/2024	9,764
20/11/2024	8,951
21/11/2024	7,056
22/11/2024	2,301
23/11/2024	8,461
24/11/2024	7,838
25/11/2024	8,652

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL