

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

4/02/2025

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
21/01/2025	8,805
22/01/2025	8,041
23/01/2025	8,175
24/01/2025	8,671
25/01/2025	8,181
26/01/2025	8,488
27/01/2025	7,884

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL