

**Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647**

Date Data Published:

12/02/2025

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
4/02/2025	8,459
5/02/2025	6,767
6/02/2025	13,974
7/02/2025	9,857
8/02/2025	9,690
9/02/2025	10,924
10/02/2025	10,436

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day



SUSTAINABLE BATHURST
A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL