

**Bathurst Regional Council**  
**Waste Water Treatment Works**  
**EPA Licence Number 1647**

Date Sample Taken: 2/04/2025  
 Date Sample Received at Laboratory: 3/04/2025  
 Date Data Received from Laboratory: 14/04/2025  
 Date Data Published: 17/04/2025  
 Data Published within 14 days: Yes

**Point 1- Weekly Sample**  
**Discharge to Macquarie River**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
<b>Limit</b>	<b>30</b>	<b>600</b>	<b>20.0</b>	<b>10</b>	<b>6.5 - 8.5</b>	<b>2.00</b>	<b>30</b>
2/04/2025	2	5	5.9	2	7.6	0.47	5
Exceedance	No	No	No	No	No	No	No

**Point 3 - Weekly/Monthly Sample**  
**Environmental Monitoring 50m Downstream of Point 1**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
2/04/2025	NR	880	NR	NR	NR	NR	NR

**Point 4 - Weekly/Monthly Sample**  
**Environmental Monitoring Upstream of Wastewater Treatment Works**

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
2/04/2025	NR	340	NR	NR	NR	NR	NR

**Notes**

mg/L = milligrams per litre

CFU/100mL = colony forming units per 100 millilitres

Monitoring and Recording Conditions: Point 1 - All pollutants monitored weekly. Points 3 & 4 - Faecal Coliforms monitored weekly, all other pollutants monitored monthly.

NR = Not required



**SUSTAINABLE BATHURST**  
 A BETTER FUTURE  
 AN INITIATIVE OF BATHURST REGIONAL COUNCIL