

Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647

Date Data Published:

9/05/2025

Data Published within 14 days:

Yes

Point 1 - Final Effluent

| Date | Volume Discharged |
|------------|-------------------|
| | kL/d |
| 29/04/2025 | 9,367 |
| 30/04/2025 | 8,880 |
| 1/05/2025 | 8,999 |
| 2/05/2025 | 10,580 |
| 3/05/2025 | 8,980 |
| 4/05/2025 | 8,634 |
| 5/05/2025 | 8,727 |

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day