

Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647

Date Data Published:

19/05/2025

Data Published within 14 days:

Yes

Point 1 - Final Effluent

Date	Volume Discharged
	kL/d
6/05/2025	8,957
7/05/2025	8,751
8/05/2025	9,106
9/05/2025	8,892
10/05/2025	8,896
11/05/2025	8,948
12/05/2025	9,309

Note: For Volume Discharged the limit of 16,500 kL/d applies only during dry weather conditions.

Summary of Units of Measure

kL/d = kilolitres per day