

Bathurst Regional Council
Waste Water Treatment Works
EPA Licence Number 1647

Date Sample Taken: 4/06/2025
 Date Sample Received at Laboratory: 5/06/2025
 Date Data Received from Laboratory: 16/06/2025
 Date Data Published: 23/06/2025
 Data Published within 14 days: Yes

Point 1- Weekly Sample
Discharge to Macquarie River

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
Limit	30	600	20.0	10	6.5 - 8.5	2.00	30
4/06/2025	2	5	9.4	2	7.3	0.50	5
Exceedance	No	No	No	No	No	No	No

Point 3 - Weekly/Monthly Sample
Environmental Monitoring 50m Downstream of Point 1

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
4/06/2025	NR	240	NR	NR	NR	NR	NR

Point 4 - Weekly/Monthly Sample
Environmental Monitoring Upstream of Wastewater Treatment Works

Date	BOD	Faecal Coliforms	Total Nitrogen	Oil and Grease	pH	Total Phosphorus	Total Suspended Solids
	mg/L	CFU/100mL	mg/L	mg/L		mg/L	mg/L
4/06/2025	NR	100	NR	NR	NR	NR	NR

Notes

mg/L = milligrams per litre

CFU/100mL = colony forming units per 100 millilitres

Monitoring and Recording Conditions: Point 1 - All pollutants monitored weekly. Points 3 & 4 - Faecal Coliforms monitored weekly, all other pollutants monitored monthly.

NR = Not required



SUSTAINABLE BATHURST
 A BETTER FUTURE
AN INITIATIVE OF BATHURST REGIONAL COUNCIL